



Compliance Statement

ISO/IEC, EN & TIA Screened Class E_A / Category 6A Two Connector Permanent Link

Elbro AG
Gewerbestrasse 4
CH-8162 Steinmaur, Switzerland

Compliance Statement No. 111675A

This type of Class E_A / Category 6A screened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6A requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the permanent link type in T568B designation connected with RJ 45 plugs from Elbro, P/N G6S-90 000. The qualification may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 12 month intervals. The permanent link consists of the following components:

<i>Cable:</i>	<i>Horizontal Cable from Draka Communications,</i>	<i>Silverline Gold - P/N STP-10 475-x</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardw.:</i>	<i>Keystone Jack from Elbro,</i>	<i>P/N COS-90 010-61</i>
	<i>Patch Panel from Elbro:</i>	<i>having PCB Marking Cat.6 R001-87603</i>
		<i>P/N COS-51 124-1</i>
		<i>having PCB Marking Cat.6A 001-0880</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 29th June 2012

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 29th June 2012

Poul Villien

Poul Villien
Coordinating Manager